






LVED0404

LAB SMALL 5 HP DUPLEX
VANE VACUUM ENCLOSURE
120G TANK

REVISION NOTES		
DESCRIPTION	ECN	PR/NOR
PRODUCTION RELEASE	PXEC0099	N/A




- NOTES:
- APPROX SYSTEM WEIGHT: 1763 LB
 - 24" MINIMUM MAINTENANCE CLEARANCE RECOMMENDED ALL SIDES. CLEARANCE FOR CONTROL PANEL SHALL BE IN ACCORDANCE WITH OSHA/NEC REQUIREMENTS

SYMBOL LEGEND		DRAWINGS TO CONFORM TO CURRENT REVISION OF THE FOLLOWING ANSI STANDARDS:		
TOLERANCES NOT SPECIFIED	SOLID EDGE DRAWING	Y14.3 MULTI AND SECTIONAL VIEW DIMS	Y14.5 DIMENSIONING AND TOLERANCING	
0.XXX ± .05	INCH	DO NOT SCALE DRAWING FOR DIMENSIONS		
0.XXX ± .005		SHEET 1 OF 2	SCALE 1:10	
<small>CONFIDENTIAL DISCLOSURE</small> This drawing is the property of POWEREX of the SCOTT FETTER COMPANY and is subject to return on demand. Its contents are confidential and must not be copied or submitted to outside parties for use or examination.		AUTHOR	ORIGINATION DATE	APPROVALS ON FILE IN PLM
<small>ITR#:</small> 71776 <small>MATERIAL:</small> SEE COMPONENT DRAWINGS <small>DESCRIPTION:</small> LAB SMALL 5 HP DUPLEX VANE VACUUM ENCLOSURE 120G TANK	ASoulek	2/7/2019		
DRAWING NUMBER LVED0404		REVISION B	SIZE D	

LVED0404

LAB SMALL 5 HP DUPLEX
VANE VACUUM ENCLOSURE
120G TANK

REVISION NOTES		
DESCRIPTION	ECN	PR/NOR
PRODUCTION RELEASE	PXEC0099	N/A



NOTE:
A 1/4 INCH VENT PLUG IS LOCATED
IN EACH FILTER HOUSING.

LEGEND	
TSH	TEMP. SWITCH
	AIR FILTER
	BALL VALVE
	VACUUM TRANSDUCER
	CHECK VALVE
	FLEX LINE
	UNION

- NOTES:
1) TSH - TEMPERATURE SWITCH HIGH
2) PER NFPA THE SYSTEM WILL REQUIRE A SOURCE VALVE (SUPPLIED BY OTHERS).
3) OUTLET SILENCER AND FLEX HOSES SHIP LOOSE FOR FIELD INSTALLATION.

SYMBOL LEGEND		DRAWINGS TO CONFORM TO CURRENT REVISION OF THE FOLLOWING ANSI STANDARDS: Y14.3 MULTI AND SECTIONAL VIEW DWGS Y14.5 DIMENSIONING AND TOLERANCING	
TOLERANCES NOT SPECIFIED	SOLID EDGE DRAWING	DO NOT SCALE DRAWING FOR DIMENSIONS	
0.XXX ± .05	INCH	SHEET 2 OF 2	SCALE I:1
0.XXX ± .005		APPROVALS ON FILE IN PLM	
<small>CONFIDENTIAL DISCLOSURE</small> This drawing is the property of POWEREX or the SCOTT FETTER COMPANY and is subject to return on demand. Its contents are confidential and must not be copied or submitted to outside parties for use or examination.		A Soulek	2/7/2019
TITLE: 71776 MATERIAL: SEE COMPONENT DRAWINGS		 150 PRODUCTION DRIVE, HARRISON OH 45030 (888) 768-7079	
DESCRIPTION: LAB SMALL 5 HP DUPLEX VANE VACUUM ENCLOSURE 120G TANK	DRAWING NUMBER: LVED0404	REVISION: B	SIZE: D

