



10HP LAB OPEN SCROLL QUADPLEX 200GAL DUPLEX DESICCANT

POWERX®




SYMBOL LEGEND		DRAWINGS TO CONFORM TO CURRENT REVISION OF THE FOLLOWING ANS I STANDARDS: Y14.3 M&T1 AND SECTIONAL VIEW DWGS Y14.5 DIMENSIONING AND TOLERANCING	
 		DO NOT SCALE DRAWING FOR DIMENSIONS	
TOLERANCES, UNLESS OTHERWISE SPECIFIED 0.XX ± .05 0.00X ± .005 $\frac{\text{---}}{\text{---}} \pm \frac{\text{---}}{\text{---}}$		SHEET 1 OF 2	
SOLID EDGE DRAWING INCH [mm]		SCALE 1:1	
CONFIDENTIAL DISCLOSURE This drawing is the property of POWEREX INC. of HARRISON HOLDINGS, INC. and is subject to return on demand. Its contents are confidential and must not be copied or submitted to outside parties for use or examination.			
AUTHOR Spraul, Kelly		REVISION DATE 07/15/25	
APPROVALS ON FILE IN PLM			
ITEM NO: 761067		150 PRODUCTION DRIVE, HARRISON OH 45030 (888) 769-7979	
MATERIAL: ---		DRAWING NUMBER L5010C5xP5	
DESCRIPTION 10HP LAB OPEN SCROLL QUADPLEX 200GAL DUPLEX DESCANT		REVISION C	
		SIZE D	


LSQ10C5xP5

10HP LAB OPEN SCROLL QUADPLEX 200GAL DUPLEX DESICCANT

REVISION NOTES	
DESCRIPTION	ECN
ADDED DRYER SAMPLE PORTS; REMOVED DRYER PRV; REMOVED CO MONITOR PLUMBING	PXEC0318



- NOTES:
- IF LAST COMPRESSOR PLEX IS ENERGIZED ALARM WILL OCCUR.
 - PIPING TO THE INLET BY OTHERS AND TO BE PER NFPA99 4-3.1.19(b)
 - INSTRUMENTS DOWN STREAM OF SOURCE VALVE TO BE SUPPLIED BY OTHERS.
 - SI EL ÚLTIMO COMPRESOR SE ACTIVA, SE PRODUCIRÁ UNA ALARMA.
 - TUBERÍA DE ADMISION POR OTROS Y CUMPLIR CON LA NFPA 99 4-3.1.19 (b).
 - ACCESORIOS AGUAS-ABAJO DE LA VALVULA DE CORTE DE SUMINISTRO SERAN INSTALADOS POR OTROS.

SYMBOL LEGEND		DRAWINGS TO CONFORM TO CURRENT REVISION OF THE FOLLOWING AND STANDARDS: Y14.3 MULTI AND SECTIONAL VIEW DWGS Y14.5 DIMENSIONING AND TOLERANCING		
	TOLERANCES, UNLESS OTHERWISE SPECIFIED	DO NOT SCALE DRAWING FOR DIMENSIONS		
0.XX ± .05	SOLID EDGE DRAWING	SHEET 2 OF 2		SCALE 1:1
0.XXX ± .005				
± .1				
INCH [mm]				
CONFIDENTIAL DISCLOSURE This drawing is the property of POWEREX INC. of HARRISON HOLDINGS, INC. and is subject to return on demand. Its contents are confidential and must not be copied or submitted to outside parties for use or examination.		AUTHOR	REVISION DATE	APPROVALS ON FILE IN PLM
ITEM ID: 761067		Spraul, Kelly	07/15/25	
MATERIAL: --		POWEREX® 150 PRODUCTION DRIVE, HARRISON OH 45030 (888) 786-7979		
DESCRIPTION 10HP LAB OPEN SCROLL QUADPLEX 200GAL DUPLEX DESICCANT		DRAWING NUMBER LSQ10C5xP5	REVISION C	SIZE D

